

Mymesh Product Sheet

Connect any light, anywhere.

MYMESH-CEDRP

Plug-in Directional Passive Infra Red (PIR) Occupancy Detector & Photocell

(Input: 100-240 Vac 50/60Hz)

This directional MYMESH-CEDRP can plug into a ceiling mounted socket (not included) - DANLERS Product Code: MYMESH-CESO. The socket can be mounted onto an appropriate BESA box or pattress box. Configurable for any room occupancy style, via the Mymesh App.

Installation:

Please read these instructions before installing the product.

NOTE: MYMESH-CEDRP is compatible with Mymesh commissioning tools.

To be installed by a competent person with reference to BS 7671 or equivalent local standards. If in doubt consult a qualified electrician.

- Plan where the MYMESH-CEDRP is to be located (see diagram 1). Switch off supply and check for hidden cables and pipes.
- The MYMESH-CEDRPplugs into a ceiling mounted socket (not included) - Product Code: MYMESH-CESO.
- The MYMESH-CEDRP should be connected as shown in diagram 2:

L - Live in. N - Neutral in.

Operation:

To check the operation of the MYMESH-CEDRP:

- Turn on the supply then after 20 seconds if the sensor has recognised movement of a person within its zone of detection the integral red LED on MYMESH-CEDRP will stay illuminated for 4 seconds before the red LED turns off.
- Thereafter, every time movement is detected by MYMESH-CEDRP the integral red LED will stay illuminated for 4 seconds.

The control also features adjustable time out (time lag) control and daylight threshold control which are configured via the Mymesh App.



Precautions:

- Do not place the MYMESH-CEDRP near heat sources, fans or in ventilated ceiling voids.
- MYMESH-CEDRP can be wired in parallel (sharing the same Live and Neutral).
- Do not place close to, or positioned such that, any light source points directly into the MYMESH-CEDRP.
- Ensure wires and cables are securely held within the connection terminals.
- The MYMESH-CEDRP should be protected by a 5 or 6 Ampere mcb or fuse.
- Disconnect the MYMESH-CEDRP from the circuit before performing insulation testing of the wiring circuit.

Status LED blinking sequence:

See diagram 6 overleaf.

Normal: Both LED's off.

Identification of device: Red LED blinks.

MYMESH-CEDRP: Technical Specifications

DIAGRAM 1: Detection




DIAGRAM 2: Wiring:




DIAGRAM 3: Dimensions:





DIAGRAM 4: Status LED:



Technical details:

INPUT	
Voltage:	100 - 240Vac
Frequency:	50/60Hz
Max. mains current:	20mA
Standby current:	14mA
RADIO TRANSCEIVER	
Operating frequencies:	2.4 2,480 GHz
Max. output power:	+4 dBm
LUX PARAMETERS	
Range:	5 - 2000 lux
OPERATING CONDITIONS Note: The temperature difference between the detection target and the background must be at least 4 °C.	
Ambient temperature:	-20 +40 °C (lout 20mA)
Storage temperature:	-25 +75 °C
Max. relative humidity:	0 80%, non cond.
CONNECTORS	
Terminal block Wire size:	0.5mm² - 2.5mm² solid or stranded
Wire strip length:	6-7mm
Tightening torque:	0,4 Nm/4 Kgf.cm
MECHANICAL DATA	
Dimensions:	74mm x 90mm x 140mm
Weight:	172g (unpacked)
Degree of protection:	IP20
Protection class:	Built-in Class 2
Material (casing)	Flame-retardant polycarbonate
Finish / Colour	Matt /White (RAL 9003)
Protection class:	Built-in Class 2
CONFORMITY AND STANDARDS	
EMC emission: EN 301 489-1 V2.2.0, EN 301 484-3, EN 55032: 2015, EN61000-3-2: 2014, EN61000-3-3: 2013	
EMC immunity: EN 301 489-1 V2.2.0, EN 301 484-3	
Environment: Complies with WEEE and RoHS directives	
CB scheme: IEC60669-1:1998, IEC60669-1:1998/AMD1:199 IEC60669-1:1998/AMD2:200 IEC60669-2:2002, IEC60669-2-1:2002/AMD1:200 Radio:	06,
Naulu.	

5 YEAR WARRANTY

EN 300 440

MYMESH-CEDRP comes with a 5 year warranty from the date of manufacture and is CE marked.

